

## TEST REPORT

Report No.: **2401100064**

Page 1 of 2  
Date: 23-01-2024

Issued To:

**M/s MQB MERCANTILES PRIVATE LIMITED**  
10/2, Lottegollahalli, Outer Ring Road, R.M.V. Extension II Stage,  
Bengaluru, Bengaluru Urban, Karnataka, 560094

Sample Description : CLOISTER UPVC PROFILE  
Sample Received Date : 10-01-2024  
Sample Drawn By : Client  
Specification : --  
Test Requested : FLAMMABILITY  
Test Method : Refer to Attached Pages.  
Test Result : Refer to Attached Pages.

Authentication: To Check authenticity of Test report (s), Scan QR code to get original data.

### SAMPLE PICTURE



**BIS, DGQA & Various Govt. Approved Laboratory**

**ISO 9001 : 2015, ISO 14001:2015 & OHSAS 18001:2007 Certified Laboratory**

Terms & Conditions:

1. Sample will not be retained more than one month for chemical and three month for mechanical unless specified instructed. 2. Samples analysis conducted on as received basis and followed by customer description, unless specified otherwise. 3. The laboratory will not be liable for sample destroy/damage during testing, unless instructed otherwise. 4. Any Complaints matter about this report should be communicated in written, within 7 days of issue of this report. 5. The result listed refer only to the tested samples and applicable parameters as described by customer. Endorsement of product is neither inferred nor implies. 6. Total liability of our laboratory is limited to the invoiced amount only. 7. This report cannot be used as and evidence in a court of law without the written approval of the laboratory.

MSF 5.10.01





# ATMY ANALYTICAL LABS PVT.LTD.

I-30, DLF Industrial Area, Phase-1, Faridabad (Haryana) INDIA  
Phone: +91-129-4019544  
info@atmylabs.com, www.atmylabs.com

- Testing
- Research
- Innovation

## TEST REPORT

Report No.: 2401100064

Page 2 of 2  
Date: 23-01-2024

UPVC PROFILE

Test performed on : 10-01-2024 to 23-01-2024

Test Parameter	Unit	Result	Test Method
Flammability	-	Self- Extinguished (Rating V-0)	UL-94

-----End of Report-----



Rahul  
ASSISTANT MANAGER-  
TESTING

Authorised Signatory



Authentication: To Check authenticity of Test report (s), Scan QR code to get original data.

BIS, DGQA & Various Govt. Approved Laboratory

ISO 9001 : 2015, ISO 14001:2015 & OHSAS 18001:2007 Certified Laboratory

Terms & Conditions:

1. Sample will not be retained more than one month for chemical and three month for mechanical unless specified instructed. 2. Samples analysis conducted on as received basis and followed by customer description, unless specified otherwise. 3. The laboratory will not be liable for sample destroy/damage during testing, unless instructed otherwise. 4. Any Complaints matter about this report should be communicated in written, within 7 days of issue of this report. 5. The result listed refer only to the tested samples and applicable parameters as described by customer. Endorsement of product is neither inferred nor implies. 6. Total liability of our laboratory is limited to the invoiced amount only. 7. This report cannot be used as and evidence in a court of law without the written approval of the laboratory.

MSF 5.10.01

